

Provisional Trajectory of Reliability Indices for FY 2025-26 to 2030-31, for the HPSEBL, approved vide Commission's letter No. HPERC/MSCH1)-18/2025-Vol-IX-3810-12 Dated 07.01.2026

Year	Area	SAIDI	SAIFI	CAIDI	CAIFI
2025-26	Urban	903.77	34.89	41.12	53.62
	Rural	993.85	35.17	35.95	44.17
2026-27	Urban	898.34	34.68	40.87	53.30
	Rural	987.89	34.96	35.74	43.90
2027-28	Urban	892.06	34.44	40.59	52.93
	Rural	980.97	34.71	35.49	43.59
2028-29	Urban	884.92	34.16	40.26	52.51
	Rural	973.13	34.44	35.20	43.24
2029-30	Urban	876.95	33.85	39.90	52.03
	Rural	965.34	34.16	34.92	42.90
2030-31	Urban	868.18	33.51	39.50	51.51
	Rural	955.69	33.82	34.57	42.47

This provisional trajectory has been approved till such time the consumers, feeders and DTRs starts getting metered through Smart Meters. However, the HPSEBL shall ensure that, for consumers metered through smart meters, the calculation of Reliability Indices is carried out on the basis of data collected, without any human intervention, through smart meters.